



NOTE

RISERS TO BE CONSTRUCTED WHERE SEWER DEPTH EXCEEDS 12'-0". FOR PIPE MATERIAL SEE SPECIFICATIONS ON PLANS.

GREATER THAN 45 ° CONNECTION TO MAIN NOT ALLOWED

TYPICAL RISER FOR SERVICE LATERAL

Fox Metro
Water Reclamation District

DESIGNED FMWRD	REVISION	2010
DRAWN KWZ	C 45° Note Added	02/02/05
APPROVED JH	D Riser & Stone Note	01/30/06
DATE 05-15-00	E Riser & Conflict Notes	03/19/07
SCALE NTS	F Conflict Note	04/29/08
SHEET 1	CAD DWG.	REVISION E
OF 1	JOB NO.	